



**CITY OF ASHEBORO
SYSTEM PERFORMANCE REPORT
JANUARY 1, 2014 - DECEMBER 31, 2014**

THIS REPORT IS COMPILED AND SUBMITTED IN ACCORDANCE
WITH HOUSE BILL 1160 – CLEAN WATER ACT OF 1999.

CITY OF ASHEBORO
DIVISION OF WATER RESOURCES
WASTEWATER TREATMENT DEPARTMENT
POST OFFICE BOX 1106
ASHEBORO, NORTH CAROLINA 27204-1106

Contact Person:

Mr. John Ogburn, City Manager
Post Office Box 1106
Asheboro, North Carolina 27204-1106
Phone: (336) 626-1200

Wastewater Treatment Plant
Operator In Responsible Charge:
Mr. Michael Ray Wiseman
Phone: (336) 672-0892, Ext. 211

Systems Maintenance
Operator In Responsible Charge:
Mr. Jeffrey Dean Cagle
Phone: (336) 672-0892, Ext, 205

Water/Sewer Maintenance Superintendent
Operator In Responsible Charge:
Mr. Andrew Connor
Phone: (336) 626-1234, Ext. 2201

Assistant Water/Sewer Maintenance Superintendent
Back up ORC:
Mr. David Johnson
Phone: (336) 626-1234, Ext. 2205

**CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT
PAGE -2-**

Water/Sewer Maintenance
Back up ORC:
Mr. Jacob Helms
Phone: (336) 460-4221

Water/Sewer Maintenance
Back up ORC:
Mr. Robbie Shortridge
Phone: (336) 626-1234, Ext. 2204

Water/Sewer Maintenance
Back up ORC:
Mr. Louis Bivins
Phone: (336) 301-5198

Public Works Director
Operator In Responsible Charge:
Mr. David Hutchins
Phone: (336) 626-1234, Ext. 2202

APPLICABLE PERMITS:

NPDES Permit No. NC0026123

Wastewater Collection System Permit No. WQCS00025

COLLECTION SYSTEM PROCESS:

Gravity Collection System – 205.6 Miles
Force Main – 25.7 Miles

LIFT STATIONS: 24

TREATMENT PLANT SYSTEM:

Includes: Preliminary treatment, primary treatment, biological trickling filters, secondary treatment, nitrification aeration, final clarification, sand filters, chlorination, disinfection and dechlorination.

**CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT
PAGE -3-**

TREATMENT PLANT PERFORMANCE

During the twelve-month period from January 1, 2014 through December 31, 2014, total flow for the wastewater treatment plant was 1,328,481,000 gallons.

During the period from January 1, 2014 through December 31, 2014, the City of Asheboro experienced zero (0) overflow events at the Wastewater Treatment Plant, nine (9) overflow events from lift stations and twelve (12) overflow events from the collection system. This amounted to a total of 576,795 gallons of wastewater overflow from lift stations and the wastewater treatment plant and 66,050 gallons overflowing from manholes, which represents only 0.04 percent of the total flow treated for this calendar year.

TREATMENT PLANT

0

LIFT STATIONS:

January 11, 2014	4,200 Gallons	Lift Station #4 – 577 Lexington Road - NOV
March 07, 2014	57,720 Gallons	Lift Station #6 – 15 Richland Place - NOV
March 07, 2014	43,825 Gallons	Lift Station #3 – 1129 E. Mine Street - NOV
March 07, 2014	344,640 Gallons	Lift Station #2 – 1229 E. Dixie Drive – NOV
March 07, 2014	90,000 Gallons	Lift Station #4 – 577 Lexington Road – NOV
April 07, 2014	6,350 Gallons	Lift Station #3 – 1129 E. Mine Street – NOV
April 07, 2014	2,100 Gallons	Lift Station #2 – 1229 E. Dixie Drive – NOV
July 25, 2014	25,000 Gallons	Lift Station #3 – 1129 E. Mine Street – NOV
September 19, 2014	2,960 Gallons	Lift Station #19 – 1065 Chamberlain Drive – NOV

**CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT
PAGE -4-**

**COLLECTION SYSTEM: (ALL THE FOLLOWING OVERFLOW EVENTS WERE
FROM MANHOLES)**

January 11, 2014	10,500 Gallons	832 Mark Avenue – NOV
February 02, 2014	10,500 Gallons	2703 Old Cox Road - NOV
February 19, 2014	28,000 Gallons	Outfall area near Lift Station #9 – NOV
February 26, 2014	750 Gallons	US 220 & McDowell Road – NOV
March 07, 2014	1,200 Gallons	712 S. Main Street - NOV
April 07, 2014	7,500 Gallons	940 Old Liberty Road – NOV
April 07, 2014	600 Gallons	1831 North Fayetteville Street – NOV
April 23, 2014	200 Gallons	2142 Golda Avenue – NOV
July 22, 2014	225 Gallons	Northeast Outfall @ Haskett’s Creek – NOV
October 17, 2014	4,500 Gallons	343 NC Hwy 42 N – NOV
November 21, 2014	950 Gallons	818 Hammer Avenue – NOV
December 26, 2014	1,125 Gallons	711 W. Kivett Street – NOV

**CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT
PAGE -5-**

City of Asheboro drinking water was not affected by any of these overflow events. Necessary measures were taken by both Water/Sewer Maintenance and Systems Maintenance personnel to address, correct, and minimize these overflow events. The Division of Water Resources in Winston-Salem was notified of each of these overflow events.

NOTIFICATION: This report is available to the public and can be reviewed by calling (336) 626-1234, ext. 2210 to make an appointment. This report can also be reviewed on the city's website at www.ci.asheboro.nc.us.

Public Notice of this report was published in The Courier-Tribune on February 25, 2015.