

**CITY OF ASHEBORO
SYSTEM PERFORMANCE REPORT
JANUARY 1, 2006– DECEMBER 31, 2006**

THIS REPORT IS COMPILED AND SUBMITTED IN ACCORDANCE
WITH HOUSE BILL 1160 – CLEAN WATER ACT OF 1999.

CITY OF ASHEBORO
DIVISION OF WATER RESOURCES
WASTEWATER TREATMENT DEPARTMENT
POST OFFICE BOX 1106
ASHEBORO, NORTH CAROLINA 27204-1106

CONTACT PERSON:
MR. JOHN OGBURN, CITY MANAGER
POST OFFICE BOX 1106
ASHEBORO, NORTH CAROLINA 27204-1106
PHONE: (336) 626-1200

WASTEWATER PLANT OPERATOR IN
RESPONSIBLE CHARGE:
MR. KIRK T. MILLER
PHONE: (336) 672-0892

SYSTEMS MAINTENANCE OPERATOR IN
RESPONSIBLE CHARGE:
MR. JEFFREY DEAN CAGLE
PHONE: (336) 873-8626

WATER/SEWER MAINTENANCE OPERATOR
IN RESPONSIBLE CHARGE:
MR. MARK DAWALT
PHONE: (336) 629-9933

ASSISTANT WATER/SEWER MAINTENANCE
OPERATOR IN RESPONSIBLE CHARGE:
MR. STEVE WOOD
PHONE: (336) 625-9352

APPLICABLE PERMITS:

NPDES PERMIT NO. NC0026123
WASTEWATER COLLECTION SYSTEM PERMIT NO. WQCS00025

COLLECTION SYSTEM PROCESS:

GRAVITY COLLECTION SYSTEM – 191 MILES

**CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT
PAGE -2-**

LIFT STATIONS: 18

TREATMENT PLANT SYSTEM:

INCLUDES: PRELIMINARY TREATMENT, PRIMARY TREATMENT, BIOLOGICAL TRICKLING FILTERS, SECONDARY TREATMENT, NITRIFICATION AERATION, FINAL CLARIFIERS, SAND FILTERS, CHLORINATION DISINFECTION AND DECHLORINATION.

TREATMENT PLANT PERFORMANCE

DURING THE TWELVE-MONTH PERIOD FROM JANUARY 1, 2006 THROUGH DECEMBER 31, 2006, TOTAL FLOW FOR THE WASTEWATER TREATMENT PLANT WAS 1,396,040,000 GALLONS.

DURING THE PERIOD FROM JANUARY 1, 2006 THROUGH DECEMBER 31, 2006 THE CITY OF ASHEBORO THIRTEEN (13) EXPERIENCED OVERFLOW EVENTS FROM THE LIFT STATIONS AND EIGHT (8) OVERFLOW EVENTS FROM THE COLLECTION SYSTEM. THIS AMOUNTED TO A TOTAL OF 50,490 GALLONS OF WASTERWATER OVERFLOWING FROM LIFT STATIONS AND 166,800 GALLONS OVERFLOWING FROM MANHOLES, WHICH REPRESENTS ONLY 0.02 PERCENT OF THE TOTAL FLOW TREATED FOR THIS CALENDAR YEAR. THERE WERE NO PERMIT VIOLATIONS DURING THIS TWELVE-MONTH REPORTING PERIOD.

LIFT STATIONS/TREATMENT PLANT:

MAR. 29, 2006	11,025 GALLONS	LIFT STATION #12 – 754 NEW CENTURY DRIVE
APRIL 4, 2006	2,000 GALLONS	1032 BONKEMEYER DRIVE
APRIL 25, 2006	4,000 GALLONS	1032 BONKEMEYER DRIVE
JUNE 23, 2006	6,750 GALLONS	LIFT STATION #3 – E. MINE STREET
	5,250 GALLONS	LIFT STATION #4 – LEXINGTON ROAD
JULY 5, 2006	1,450 GALLONS	LIFT STATION #3 – E. MINE STREET
OCT. 16, 2006	75 GALLONS	LIFT STATION #3 – E. MINE STREET
NOV. 16, 2006	3,150 GALLONS	LIFT STATION #3 – E. MINE STREET

**CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT**

PAGE -3-

NOV. 22, 2006	3,900 GALLONS	LIFT STATION #4 – LEXINGTON RD
	1,350 GALLONS	LIFT STATION #4 – LEXINGTON RD.
	3,345 GALLONS	LIFT STATION #3 – E. MINE STREET
	3,195 GALLONS	LIFT STATION #3 – E. MINE STREET
DEC. 25, 2006	5,000 GALLONS	LIFT STATION #3 – E. MINE STREET

COLLECTION SYSTEM: (ALL THE FOLLOWING OVERFLOW EVENTS WERE FROM
MANHOLES)

JAN. 12, 2006	800 GALLONS	BEHIND 419 OLD LIBERTY ROAD
MAR. 15, 2006	95,000 GALLONS	END OF SPRING GARDEN STREET
MAY 16, 2006	9,500 GALLONS	END OF ENGLISH STREET
SEPT. 7, 2006	7,500 GALLONS	SOUTH OF 3077 FOREST PARK DRIVE
NOV. 16, 2006	10,000 GALLONS	BREWER @ MEADOWBROOK STREETS
NOV. 22, 2006	35,000 GALLONS	BEHIND 649 WOODLAND CIRCLE
DEC. 14, 2006	4,000 GALLONS	END OF MOODY STREET
DEC. 21, 2006	5,000 GALLONS	BEHIND 230 HUGHES STREET

CITY OF ASHEBORO DRINKING WATER WAS NOT AFFECTED BY ANY OF THE
REPORTED OVERFLOW EVENTS.

NECESSARY MEASURES WERE TAKEN BY BOTH WATER/SEWER MAINTENANCE AND
SYSTEMS MAINTENANCE TO ADDRESS, CORRECT AND MINIMIZE THESE OVERFLOW
EVENTS. THE DIVISION OF WATER QUALITY IN WINSTON-SALEM WAS NOTIFIED OF
EACH OF THESE OVERFLOW EVENTS.

NOTIFICATION: THIS REPORT IS AVAILABLE TO THE PUBLIC AND CAN BE
REVIEWED BY CALLING (336) 626-1234, EXT. 2210 TO MAKE AN
APPOINTMENT.

**CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT**
PAGE -4-

NOTIFICATION OF THE AVAILABILITY OF THIS REPORT WILL BE PRINTED ON ALL WATER BILLS MAILED TO CITY OF ASHEBORO WATER CUSTOMERS AT THE NEXT BILLING CYCLE.

PUBLIC NOTICE OF THIS REPORT WAS PUBLISHED IN THE COURIER-TRIBUNE ON WEDNESDAY, MARCH 7, 2008. A COPY OF THE NOTICE IS ATTACHED.

CERTIFICATION:

THIS IS TO CERTIFY THAT THE INFORMATION CONTAINED HEREIN IN THIS REPORT IS TRUE AND ACCURATE TO THE BEST OF MY KNOWLEDGE.

SIGNED: _____ DATE: _____
(DIRECTOR OF WATER RESOURCES)