



**CITY OF ASHEBORO
SYSTEM PERFORMANCE REPORT
JANUARY 1, 2021 - DECEMBER 31, 2021**

THIS REPORT IS COMPILED AND SUBMITTED IN ACCORDANCE
WITH HOUSE BILL 1160 – CLEAN WATER ACT OF 1999.

CITY OF ASHEBORO
DIVISION OF WATER RESOURCES
WASTEWATER TREATMENT DEPARTMENT
POST OFFICE BOX 1106
ASHEBORO, NORTH CAROLINA 27204-1106

Contact Person:

Mr. John Ogburn, City Manager
Post Office Box 1106
Asheboro, North Carolina 27204-1106
Phone: (336) 626-1200

Wastewater Treatment Plant
Operator In Responsible Charge:
Mr. Michael Ray Wiseman
Phone: (336) 672-0892, Ext. 211

Systems Maintenance
Operator In Responsible Charge:
Mr. Jeffrey Dean Cagle
Phone: (336) 672-0892, Ext. 205

Water/Sewer Maintenance Superintendent
Operator In Responsible Charge:
Mr. Andrew Connor
Phone: (336) 626-1234, Ext. 2201

Assistant Water/Sewer Maintenance Superintendent
Back up ORC:
Mr. Shannon White
Phone: (336) 626-1234, Ext. 2205

**2021 CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT
PAGE – 2**

Water/Sewer Maintenance
Back up ORC:
Mr. Louis Bivins
Phone: (336) 301-5198

Public Works Director
Operator In Responsible Charge:
Mr. David Hutchins
Phone: (336) 626-1234, Ext. 2202

APPLICABLE PERMITS:

NPDES Permit No. NC0026123

Wastewater Collection System Permit No. WQCS00025

COLLECTION SYSTEM PROCESS:

Gravity Collection System – 206.2 Miles
Force Main – 28.5 Miles
Low Pressure – 1.1 Miles

LIFT STATIONS: 27

TREATMENT PLANT SYSTEM:

Includes: Preliminary treatment, primary treatment, biological trickling filters, secondary treatment, nitrification aeration, final clarification, sand filters, chlorination, disinfection and dechlorination.

TREATMENT PLANT PERFORMANCE

During the twelve-month period from January 1, 2021 through December 31, 2021, total flow for the wastewater treatment plant was 1,440,480,000 gallons.

During the period from January 1, 2021 through December 31, 2021, the City of Asheboro experienced one (0) overflow events at the Wastewater Treatment Plant, seven (7) overflow events from lift stations and nine (9) overflow events from the collection system. This amounted to a total 0 gallons from the wastewater treatment plant, 48,694 gallons from lift stations, and 16,705 gallons overflowing from manholes, which represents less than 0.05 percent of the total flow treated for this calendar year.

WASTEWATER TREATMENT PLANT

0

LIFT STATIONS:

April 26, 2021	2,000 Gallons	Lift Station #1 – 1592 Sunset Ave Ext. – NOV
June 11, 2021	6,987 Gallons	Lift Station #4 – 577 Lexington Road – NOV
June 11, 2021	7,767 Gallons	Lift Station #3 – 1129 East Mine Street – NOV
June 11, 2021	6,000 Gallons	Lift Station #2 – 1229 East Dixie Drive – NOV
June 11, 2021	3,250 Gallons	Lift Station #6 – 15 Richland Place – NOV
August 7, 2021	18,840 Gallons	Lift Station #3 – 1129 East Mine Street – NOV
August 18, 2021	3,850 Gallons	Lift Station #3 – 1129 East Mine Street - NOV

**COLLECTION SYSTEM: (ALL THE FOLLOWING OVERFLOW EVENTS WERE
FROM MANHOLES)**

January 31, 2021	4,550 Gallons	224 Crestview – NOV
February 16, 2021	1,005 Gallons	Sanford Street Outfall – NOV
February 16, 2021	330 Gallons	715 East Presnell Street – NOV
March 16, 2021	2,925 Gallons	Behind 240 Spring Garden Street – NOV
April 4, 2021	410 Gallons	446 East Pritchard Street – NOV
November 10, 2021	2,100 Gallons	747 Lake Drive – NOV
November 11, 2021	1,580 Gallons	749 Lake Drive – NOV
November 29, 2021	2,575 Gallons	427 Highland Street – NOV
November 29, 2021	1,230 Gallons	730 Industrial Park - NOV

City of Asheboro drinking water was not affected by any of these overflow events. Necessary measures were taken by both Water/Sewer Maintenance and Systems Maintenance personnel to address, correct, and minimize these overflow events. The Division of Water Resources in Winston-Salem was notified of each of these overflow events.

**2021 CITY OF ASHEBORO ANNUAL
SYSTEM PERFORMANCE REPORT
PAGE – 4**

NOTIFICATION: This report is available to the public and can be reviewed by calling (336) 626-1201, ext. 258 to make an appointment. This report can also be reviewed on the city's website at www.ci.asheboro.nc.us.

Public Notice of this report was published in The Courier-Tribune on Sunday, February 20, 2022.

CERTIFICATION:

This is to certify that the information contained herein in this report is true and accurate to the best of my knowledge.

Signed: Michael D Rhony Date: 2/18/2022
(Water Resources Director)